



**City of Sedona Community Development Department  
Engineering Services**

102 Roadrunner Drive Sedona, AZ 86336  
(928) 204-7111 • Fax: (928) 282-5348

**To Whom It May Concern:**

The City of Sedona, Arizona is issuing **Addendum # 2** to the Contract Documents as originally issued at the time of solicitation for bid for the **Police Department Shooting Range Improvements Project**. For any submission to be considered responsible and responsive, receipt of this addendum must be acknowledged.

As specified in the Information For and Instructions to Bidders this Addendum upon issuance has become a part of the Request for Qualifications.

This Addendum contains 2 pages including this page.

*This Addendum adds the following:*

**1. Seed mix shall meet the following specifications:**

<u>SPECIES</u>	<u>PURE LIVE SEED RATE/ACRE</u>
SAND DROPSEED (SPOROBOLUS CRYPTANDRUS)	2LB
SIDEOATS GRAMA (BOUPELOUS CURTIPENDULA)	10LB
CRESTED WHEATGRASS (AGROPYRON CRISTATUM)	10LB

Hydroseeding should be per ADOT spec 805.

**ACKNOWLEDGEMENT**


I have received addendum # 2 for the **Police Department Shooting Range Improvements Project** as described above, and acknowledge it as part of the Contract Documents for the project.

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Date**

\_\_\_\_\_  
**Print Business Name**

Addendum # 2 issued by J. Andy Dickey, PE, Assistant Community Development Director/City Engineer, City of Sedona



\_\_\_\_\_  
J. Andy Dickey, PE, Assistant Community Development Director/City Engineer

7/24/14  
Date