



**City of Sedona Community Development Department
Engineering Services**

102 Roadrunner Drive Sedona, AZ 86336
(928) 204-7111 • Fax: (928) 282-5348

To Whom It May Concern:

The City of Sedona, Arizona is issuing **Addendum # 1** to the plans and specifications as originally issued at the time of solicitation for bids for the **Injection Well No. 2 Drilling Project.** For any bid to be considered responsible and responsive, receipt of this addendum must be acknowledged.

As specified in the Instructions to Bidders this Addendum upon issuance has become a part of the Contract Documents.

This Addendum contains 3 pages including this page, 0 changed bid sheets, and 0 plan sheets. Any changed bid sheets shall be used in lieu of the originally issued bid sheets in order to submit a responsive bid.

This Addendum changes the following:

1. **Change to Section 8.2.1.4, Above-Ground Booster Pump (page TS-34):** Delete the following phrase from the second sentence: "...at 300 ft total dynamic head (TDH)". Add the following after the second sentence: "A minimum of 25 "A minimum of 25 psi shall be maintained at well head at all times and flows during injection."

This Addendum adds the following:

1. The pre-bid sign in sheet is attached.
2. **Add to Technical Specification Section 8.2.1, Temporary Infrastructure for Well No. 2 Injection Test (page TS-33):** "All temporary piping shall be flushed and disinfected according to MAG Specification Section 6.11.2.1 – 6.11.2.10 (2015 edition). After achieving the specified disinfection, pipelines shall be flushed again until chlorine residuals are at or below 1mg/L."
3. **Add to Technical Specification Section 8.2.1.3, Injection Test Storage Tank (page TS-34):** "Temporary storage tank shall be a potable grade tank."

ACKNOWLEDGEMENT


I have received addendum **# 1** for the **Injection Well No. 2 Project. Project** as described above, and acknowledge it as part of the Contract Documents for the project.

Signature

Date

Print Business Name

Addendum #1 issued by J. Andy Dickey, PE, Assistant Community Development Director/City Engineer, City of Sedona



03/17/2015

J. Andy Dickey, PE Assistant Community
Development Director/City Engineer

Date

SIGN IN SHEET

Injection Well No. 2 Drilling - Pre-Bid Mtg 03/16/15

NAME	FIRM NAME	TEL. NO.	E-MAIL
Jeff Smith	Mikes Drilling	520-490-0399	wellgyv@live.com
Brian Schlieter	KP Ventures or Partner	928-639-1709	KPvent@aol.com
Rod Beeman	Sunbelt Drilling LLC	602-376-1123	info@sunbeltdrilling.com
David Stendin	Rain For Rent	602-393-7898	dshendin@rainforrent.com
DENNIS M SWIFT	PATHFINDER CONST, INC	928-567-3507	DENNIS@PATHFINDERCONSTRUCTION.NET
Roxanne Holland	City of Sedona	928-203-5069	Rtholland@sedonaaz.gov
Harold Blazherin	Drill Tech	928-636-8006	Harold@DrillTechaz.com
ERIC BOWE	YELLOW TARGET MARKS	(602) 453-3252	ERIC@YTDRAWING.COM
Nick Owens	Drill Tech drilling	928 925 8608	NickOwens@drilltechaz.com

L:\Engineering Services\WWTP\Injection Well 1 & 2\Meetings\DRILLING\Pre-Bid\2nd PREBID SIGN IN SHEET.xls\SIGN IN