



City of Sedona Community Development Department Engineering Services

102 Roadrunner Drive Sedona, AZ 86336
(928) 204-7111 • Fax: (928) 282-5348

To Whom It May Concern:

The City of Sedona, Arizona is issuing **Addendum # 2** to the plans and specifications as originally issued at the time of solicitation for bids for the **WWRP Injection Well No. 1 and Well No. 2 Equipping Project**. For any bid to be considered responsible and responsive, receipt of this addendum must be acknowledged.

As specified in the Instructions to Bidders this Addendum upon issuance has become a part of the Contract Documents.

This Addendum contains 4 pages including this page, 0 changed bid sheets, 0 plan sheets, and 0 additional Technical Specification. Any changed bid sheets shall be used in lieu of the originally issued bid sheets in order to submit a responsive bid.

This Addendum clarifies the following based on questions asked during the pre-bid meeting:

1. Questions may be submitted, in writing to Roxanne Holland, until 11:59 PM Sunday September 20, 2015. Any questions received after that time may not be answered.
2. Contractor shall be responsible to ensure that start-up services from manufacturer's are provided meeting the requirements of Specification 01756. Start-up services already included as part of the pre-procured equipment package are as follows:
 - a. On-Site Sodium Hypochlorite Generation System: One factory representative for 5 days during 1 trip to assist in installation inspection, start-up supervision, and operator training.
 - b. Cartridge Filter System: None
3. Contractor shall be responsible to provide warranty meeting the requirements of General Condition 51. Contractor shall review the pre-procurement packages from manufacturer's to identify any warranty deficiencies and shall provide additional warranties as needed to meet project specifications.
4. A building permit is required for the electrical and sodium hypochlorite buildings (building permit application and fees to be submitted by the City). Yavapai County will be conducting inspections during construction to confirm compliance with building codes. City of Sedona and/or Carollo will conduct inspections during construction to confirm compliance with project plans and specifications.
 - a. Special structural inspections required for CMU buildings include: concrete, bolts installed in concrete, reinforcing steel, structural masonry, expansion/epoxy anchors, soils, compaction, and roof deck.
 - b. Special structural inspections required for pre-cast electrical enclosures will be less expansive and limited to connection points.

This Addendum adds the following:

5. Pre-bid meeting sign-in sheet is attached.
6. Drawing 30-M-01, Keynote 1, ADD the following: Contractor shall supply and install 4,500 lb of salt meeting the manufacturer's specifications as part of startup. In addition, Contractor shall supply 4,500 lb of salt meeting the same specifications in bags no larger than 50 lb each. Salt shall be stored in location as directed by the City.

ACKNOWLEDGEMENT


I have received addendum # 2 for the WWRP Injection Well No. 1 and Well No. 2 Equipping Project as described above, and acknowledge it as part of the Contract Documents for the project.

Signature

Date

Print Business Name

Addendum # 2 issued by J. Andy Dickey, PE, Assistant Community Development Director/City Engineer,
City of Sedona



J. Andy Dickey, PE Assistant Community
Development Director/City Engineer

09/17/2015
Date

SIGN IN SHEET

WWRP Injection Well No. 1 & Well No. 2 Equipping -
Pre-Bid Conference 09/16/15 -

NAME	FIRM NAME	TEL. NO.	E-MAIL
Roxanne Holland	City of Sedona	928-203-5069	RHolland@SedonaAZ.gov
Tyrel Eckroth	Schofield Civil Construction	602-679-3600	tae@schofieldcivil.com
Randy Hodge	GHD	602-489-0684	
Michael Freid	GHD	602-881-5502	Mike.Freid@GHD.com
Michael Ottmann	Technology Construction, Inc.	928-777-0099	MikeOttmann@yahoo.com
Kelvin Ng	Ludvik	602-777-5000	kng@Ludvik.com
Mike Rivera	Currier Construction	602-274-4370	mriviera@currierinc.com
Jim Erispaha	MGC Contractors	602-437-5000	bids@mgccontractors.com
Brad Jeppson	Carollo Engineers	602-571-5776	bjepson@carollo.com
Andrew Pavey	Keller Electrical	602-757-8034	apavey@kellerelectrical.com
Graydon Cox	BEMO USA	707-344-1026	graydonc@bemousa.com
Kenny Porter	KP Ventures Drilling and Pump	928-639-1709	kpventoffice@gmail.com
J. Andy Dickey	City of Sedona	928-203-5039	adickey@sedonaaz.gov
Dan East	Garney Construction	720-348-8407	DEast@garney.com

SIGN IN SHEET

WWRP Injection Well No. 1 & Well No. 2 Equipping -
Pre-Bid Conference 09/16/15 -

NAME	FIRM NAME	TEL. NO.	E-MAIL
Bart Zichichi	OPTCO	602-525-2327	B.Z@optcoaz.com
Ruairi Moore	City of Sedona	928-239-0458	rmoore@SedonaAz.gov
Michael Young	Fann Environmental	928-778-5335	mikeyoung@fannenvironmental.com
Steve Bjerke	Weber Water Resources	520-235-8698	sbjerke@weber-waterresources.com
Ronnie Garcia	City of Sedona	928-203-5042	rgarcia@SedonaAz.gov
Jeffery Wold	Southwest Waterworks	480-599-7201	jeffwold@swwc.biz
Sal Valenzuela	City of Sedona	928-203-5030	svalenzuela@SedonaAz.gov
James Harris	Currier Construction	602-859-5924	
Jim Tackett	Currier Construction	602-859-5904	