

## PRELIMINARY WATER DESIGN MEMORANDUM

To: Erwin Architecture & Development  
From: Andrew Baird, P.E.  
Kimley-Horn and Associates, Inc.  
Date: December 14, 2022  
Subject: Arabella Spa

---

### BACKGROUND

This Preliminary Water Design Memorandum for the Arabella Spa has been prepared to address the water system requirements outlined in the City of Sedona – Design, Review, Engineering and Administrative Manual (DREAM), Arizona Water Company (AWC) and Arizona Department of Environmental Quality (ADEQ). The main purposes of this memo are the following:

- Illustrate compliance with the DREAM, AWC, ADEQ.
- Establish water demand and fire flow criteria for design.
- Establish the feasibility of the development of the site.

The project site (Site) is located along Sombart Ln. east of State Route 179. The Site is bounded to the north by property that is zoned commercial but is currently being utilized as parking for trailheads, east by a hotel complex, south by single family residential properties, and the west by property zoned open space and Coconino National Forest. The Site is located within the City of Sedona, Section 21, Township 4 South, Range 03 East. The Site consists of parcel 401-22-034B approximately 7.0 acres. See **Appendix A** for the Location Map and Vicinity Map, respectively.

As part of this project, a new spa will be constructed, including four buildings, walkways and patio space, and utilities to service the site. The water system design will include the future additions, and the infrastructure designed accounts for the ultimate condition of the Site.

### METHODOLOGY

The water system serving the Arabella Spa Site has been modeled using WaterCAD, developed using the Haestad Method. The program utilizes the fluid mechanic head loss theory known as the Hazen-Williams method. This is the generally accepted method used to evaluate water distribution systems.

### EXISTING WATER SYSTEM

An existing 8-inch DIP water line is located near the northwest corner of the existing hotel building in Sombart Lane. Hydrants are located west and north of the site in Sombart Lane.

### FIRE FLOW TEST

A Fire Hydrant Flow Test was conducted to determine capacity of the existing infrastructure to service the proposed development. Residual and static pressures were obtained from a flow test performed on three fire hydrants near the site, west of the project site in Sombart Lane and on Highway 179, by Arizona Water Company (see **Appendix C** for fire flow test results). The residual and static pressures from the flow test are included in Table 2.

Table 1: Fire Hydrant Flow Rate Test Results

Hydrant No.	Static Pressure (psi)	Hydrant Flow Test		*Calculated Maximum	
Hydrant No.		Flow (gpm)	Residual Pressure (psi)	Flow (gpm)	Minimum Pressure (psi)
FH 179	120	1379	110	4782	20
FH 181	120	1379	108	4333	20
FH 125	110	1060	65	1541	20

**HYDRAULIC MODEL**

From the static and residual pressures obtained, the calculated maximum operating flow was found to be 4,782 GPM at 20 psi. Using this data, the WaterCAD v8i water system modeling software was used to model the proposed water network. The model is calibrated with the provided existing system information and tested fire flow conditions. A fire flow test was performed to determine the residual and static pressure of the existing system. As stated above three fire flow tests were performed. However, only the flow and pressure data from hydrant 179 was used. Using the fire flow test from fire hydrant 179, a supply curve was generated, as shown below in **Figure 1**. The supply curves help model the expected flow from the existing system to the Arabella Spa water distribution system. Within the model the supply curve, and existing system connection, are modeled as a pump connected to a reservoir.




Figure 1. Pump Supply Curve

## PROPOSED WATER SYSTEM

An 8-inch DIP water line is proposed in Sombart Lane to provide domestic and fire service to the site. An 8" DIP domestic and fire service line is proposed, which will tie into an existing 8" water main on Sombart Lane near the entrance to Arabella. The 8" DIP line will connect to the line on Sombart Lane with a tapping sleeve and valve. The new 8" fire and domestic line will run from the line on Sombart southwest, as shown in the utility exhibit, with an 8" tee and reducer and a 6" DIP line that will run to building 4. A second 8" line will run south from the tee to a proposed fire suppression standpipe near the center of the site. The remainder of this run past the standpipe will be 6" PVC. The laterals to building 1 and 2 will also be 6" DIP lines. A proposed hydrant will be placed at the northwest corner of the site as well, next to the domestic service connection and will connect to the 8" main on Sombart separately. The domestic service throughout the site will be treated as a private line and will not require an easement. See **Appendix B** for the system layout.

## FIRE FLOW DEMAND

The proposed PDAB is a Construction Type I-B. The required fire flow per building was determined using the 2012 International Fire Code as adopted by City of Sedona and is based on construction type, building square footage, and provision of an approved sprinkler system. The City of Sedona allows for a maximum 75% reduction of the required fire flow for building provided that the building is equipped with an interior fire suppression sprinkler system to an absolute minimum of 1,500gpm. The minimum fire flow requirements for the proposed buildings are shown in **Table 3**. **Table 3** also shows the required building fire flow based upon a maximum fire flow reduction of 75% allowed.

**Table 2: Design Criteria for Public Water Infrastructure**

Building	Building Construction Type <sup>1</sup>	Building Area <sup>2</sup> (ft <sup>2</sup> )	Required Fire Flow <sup>3</sup> (gpm)	Reduction <sup>3</sup>	Required Fire Flow <sup>4</sup> (gpm)
1	I-B	16859	1500		1500
2	I-B	524	1500		1500
3	I-B	1915	1500		1500
4	I-B	1304	1500		1500

<sup>1</sup>Construction Type based on IBC

<sup>2</sup>Areas based on Site Plan (Appendix A)

<sup>3</sup>Fire flow requirements per Sedona Fire District use of 2012 International Fire Code. Maximum reduction = 75% <sup>4</sup>Minimum Fire Flow Requirement of 1,500 gpm per 2006 IFC

## WATER ANALYSIS AND RESULTS

The Average Daily Demand, Maximum Daily Demand, and Maximum Day Demand plus Fire Flow Demand analyses were performed, for the development, to evaluate the proposed water infrastructure. The system was analyzed to ensure that the existing and proposed public water infrastructure meets the following criteria as set forth in the DREAM and the AWC guidelines. See **Appendix C** for domestic water demand calculations.

**Table 3: Design Criteria for Public Water Infrastructure**

<i>Scenario</i>	<i>Criteria</i>	<i>Constraint</i>
Max Day + Fire Flow	Minimum Pressure	20 psi
Max Day + Fire Flow	Maximum Velocity	*10 fps
Max Day	Minimum Pressure	55 psi

The fire flow demand of 1,500 GPM was applied at the proposed fire hydrant and at the proposed standpipe in the area between the buildings. An assumed demand of 30 GPM was added at the building connections as a demand flow for a fire suppression system at each building. The minimum PSI was recorded at each node. These flows were determined based on the assumption that one building requires fire suppression at a time and the hydrant requires full flow.

As previously discussed, Maximum Day Demand plus Fire Flow Demand analyses were performed for the existing adjacent off-site water infrastructure and the proposed on-site water system. See **Appendix D** for the proposed system’s Water Model Schematics and Results. A summary of the water analysis results for the public distribution main is tabulated below:

**Table 4: Fire Flow and Maximum Daily Demand Water Model Result Summary**


<i>Criteria</i>	<i>Constraint</i>	<i>Max Day</i>	<i>Max Day + FF</i>
Minimum System Pressure	53 psi		20 psi
Maximum Velocity	10 fps*		Yes
Minimum System Pressure	55 psi	Yes	

**RECOMMENDATION**

\*Although standard practice requires a maximum velocity of 10 fps during maximum day plus fire flow demand scenarios, Arizona Water Company desires a maximum velocity of 8 fps in the system. Kimley-Horn is requesting a variance for using 10 fps as the maximum velocity requirement, as our system with 8” DIP meets this requirement with a velocity of 9.68 ft/s and maintains adequate pressure.

The proposed on-site water system and the existing, adjacent off-site public water infrastructure, as outlined by this analysis, is adequate and is sufficient to meet the required domestic water demand and fire flow demand for the proposed Arabella Spa project.

# Appendix A – Site Location Map



**LEGEND:**

- |              |   |        |                                   |      |          |
|--------------|---|--------|-----------------------------------|------|----------|
| ○ 4500       | EX. WATER VALVE & REFERENCE NUMBER              | □      | METER                             | ---- | EASEMENT |
| ⊙ FH125      | EX. FIRE HYDRANT & REFERENCE NUMBER             | ⊕      | TEE                               | ---- | WASH     |
| ○ 6" CA 1980 | EX. WATER MAIN W/ DIAMETER AND YEAR CONSTRUCTED | BO-73  | FITTING                           |      |          |
|              |   | 1"ARVP | BLOW OFF VALVE & REFERENCE NUMBER |      |          |
|              |   |        | AIR RELIEF VALVE                  |      |          |

**WATER MAIN MATERIALS:**

- CA CEMENT ASBESTOS
- PVC POLYVINYL CHLORIDE
- CLC CONCRETE LINED CYLINDER
- CU COPPER
- STL STEEL
- CI CAST IRON
- DI DUCTILE IRON
- HDPE HIGH DENSITY POLYETHYLENE
- GS GALVANIZED STEEL
- UNS UNSPECIFIED

**NE1/4 SEC.18-T.17N.,R.6E.**  
**WATER DISTRIBUTION**  
**ARIZONA WATER COMPANY**  
 PHOENIX, ARIZONA  
 SCALE: 1"= 200'-0" DATE: 8/28/2018




**SEDONA**



# Appendix B– Proposed Water System Layout

# Scenario: Base









# Appendix C– Water Demand Flows/Fire Flow Test Results

Design Water Demand Calculations												
Location	Use	Water Demand Rate		Demand Criteria		Water Design Flow [GPD]	Avg. Day Demand [GPD]	Avg. Day Demand [gpm]	*Max. Day Demand [GPD]	*Max. Day Demand [gpm]	*Peak Hour Demand [GPD]	*Peak Hour Demand [gpm]
		gpd	unit	No.	unit							
Building 1	Commercial (Building Area)	3000	acre	0.25	acres	746	746	0.52	1491	1.04	2237	1.55
	Restaurant	1.3	sqft	1951	sqft	2536	2536	1.76	5073	3.52	7609	5.28
	Developed Open Space (Patio)	3500	acre	0.39	acres	1348	1348	0.94	2696	1.87	4044	2.81
	Hot Pool	720	pool	1	pool	720	720	0.50	1440	1.00	2160	1.50
<b>Subtotal</b>						<b>5,350</b>	<b>5,350</b>	<b>3.72</b>	<b>10,700</b>	<b>7.43</b>	<b>16,050</b>	<b>11.15</b>
Building 2	Commercial (Building Area)	3000	acre	0.04	acres	109	109	0.08	218	0.15	327	0.23
	Developed Open Space (Patio)	3500	acre	0.02	acres	62	62	0.04	124	0.09	186	0.13
	Cold Pool	120	pool	1	pool	120	120	0.08	240	0.17	360	0.25
<b>Subtotal</b>						<b>291</b>	<b>291</b>	<b>0.20</b>	<b>582</b>	<b>0.40</b>	<b>873</b>	<b>0.61</b>
Building 3	Commercial (Building Area)	3000	acre	0.04	acres	131	131	0.09	261	0.18	392	0.27
	Developed Open Space (Patio)	3500	acre	0.04	acres	149	149	0.10	298	0.21	447	0.31
	Cold Pool	230	pool	1	pool	230	230	0.16	460	0.32	690	0.48
<b>Subtotal</b>						<b>510</b>	<b>510</b>	<b>0.35</b>	<b>1,019</b>	<b>0.71</b>	<b>1,529</b>	<b>1.06</b>
Building 4	Commercial (Building Area)	3000	acre	0.10	acres	286	286	0.20	573	0.40	859	0.60
	Developed Open Space (Patio)	3500	acre	0.08	acres	269	269	0.19	537	0.37	806	0.56
	Hot Pool	1500	pool	1	pool	1500	1500	1.04	3000	2.08	9000	6.25
<b>Subtotal</b>						<b>2,055</b>	<b>2,055</b>	<b>1.43</b>	<b>4,110</b>	<b>2.85</b>	<b>6,164</b>	<b>4.28</b>
Next to Building 3	Hot Pool	885	pool	1	pool	885	885	0.61	1770	1.23	2655	1.84
<b>Subtotal</b>						<b>885</b>	<b>885</b>	<b>0.61</b>	<b>1,770</b>	<b>1.23</b>	<b>2,655</b>	<b>1.84</b>
Grounds	Xeriscape	1170	acre	1.97	acres	2305	2305	1.60	4610	3.20	6915	4.80
<b>Subtotal</b>						<b>2,305</b>	<b>2,305</b>	<b>1.60</b>	<b>4,610</b>	<b>3.20</b>	<b>6,915</b>	<b>4.80</b>
<b>Total</b>						<b>11,395</b>	<b>11,395</b>	<b>7.91</b>	<b>22,790</b>	<b>15.83</b>	<b>34,186</b>	<b>23.74</b>

\*Max Day Demand is based on a Peaking Factor of 2.0

\*\*Average Daily Demands were taken from estimates provided by Arizona Water Company based on land use

**From:** Casey Goff <[cgoff@azwater.com](mailto:cgoff@azwater.com)>  
**Sent:** Thursday, September 30, 2021 7:51 AM  
**To:** Warne, James  
**Subject:** Arabella Hydrant Flows  
**Attachments:** [Scan2021-09-30\\_075026.pdf](#)

James,

Here are the hydrant flows for the surrounding fire hydrants at Arabella. These flows are somewhat old so if you need updated information, please let me know and we can schedule some flow tests. Also, see the attached portion of the ¼ section map for reference.

FH 125 Static – 110 psi  
Kinetic – 65 psi  
GPM – 1060

FH 179 Static – 120 psi  
Kinetic – 110 psi  
GPM – 1379

FH 181 Static – 120 psi  
Kinetic – 108 psi  
GPM – 1379

I hope this information helps.

Thanks,



**Casey Goff | Arizona Water Company**  
**Distribution Superintendent**  
**Verde Valley Division**

65 Coffeepot Dr. Ste #7 | Sedona, AZ 86336  
D: 928-282-7092 ext 4102 | [cgoff@azwater.com](mailto:cgoff@azwater.com)

Visit us at [www.azwater.com](http://www.azwater.com)

**Electronic File Disclaimer:** This e-mail and any attachments may contain privileged and confidential information for the sole use of the intended recipient(s). Arizona Water Company makes no guarantees nor warrants the accuracy or completeness of any of the information contained in these files, as recipients should verify all information. If you have received this correspondence in error, please notify the sender immediately by e-mail and permanently delete this message and any attachments from your computer.

**Map Disclaimer:** This map is for general reference only. It does not replace a land survey and Arizona Water Company does not guarantee its thematic or spatial accuracy.

# Appendix D- Water Model Results

# AVERAGE DAY

**FlexTable: Junction Table**  
**FlexTable: Junction Table**

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
39	FH125	4,241.70	0.00	4,502.00	113
41	J-7	4,246.87	0.00	4,502.00	110
60	J-8	4,269.00	0.00	4,502.00	101
62	J-9	4,269.60	0.00	4,502.00	101
64	J-10	4,270.30	0.00	4,502.00	100
66	J-11	4,270.00	0.00	4,502.00	100
68	J-12	4,281.40	0.00	4,502.00	95
70	J-13	4,294.60	0.00	4,502.00	90
71	J-14	4,299.00	0.00	4,502.00	88
72	J-15	4,310.30	0.00	4,502.00	83
73	J-16	4,315.00	1.43	4,502.00	81
74	J-17	4,298.40	0.00	4,502.00	88
75	J-18	4,300.40	0.00	4,502.00	87
76	J-19	4,299.90	0.35	4,502.00	87
77	J-20	4,294.50	0.61	4,502.00	90
78	J-21	4,296.80	0.20	4,502.00	89
90	J-23	4,280.00	3.72	4,502.00	96
92	J-24	4,299.60	0.00	4,502.00	88
115	J-25	4,269.70	1.60	4,502.00	101
130	J-28	4,256.20	0.00	4,502.00	106
143	J-29	4,244.84	0.00	4,502.00	111
156	J-30	4,240.00	0.00	4,502.00	113
158	J-31	4,225.50	0.00	4,502.00	120
160	FH-179	4,225.00	0.00	4,502.00	120



**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
63	P-15	8	J-8	J-9	8.0	Ductile Iron	120.0	6.31	0.04	0.0000
65	P-16	7	J-9	J-10	8.0	Ductile Iron	120.0	0.00	0.00	0.0000
67	P-17	12	J-9	J-11	8.0	Ductile Iron	120.0	6.31	0.04	0.0000
79	P-19	86	J-12	J-13	8.0	Ductile Iron	120.0	2.59	0.02	0.0000
80	P-20	14	J-13	J-14	8.0	Ductile Iron	120.0	2.39	0.02	0.0000
81	P-21	81	J-14	J-15	6.0	Ductile Iron	120.0	1.43	0.02	0.0000
84	P-23	71	J-15	J-16	6.0	Ductile Iron	120.0	1.43	0.02	0.0069
85	P-24	45	J-14	J-17	8.0	Ductile Iron	120.0	0.96	0.01	0.0000
87	P-26	64	J-18	J-19	6.0	Ductile Iron	120.0	0.35	0.00	0.0000
88	P-27	18	J-18	J-20	6.0	Ductile Iron	120.0	0.61	0.01	0.0000
89	P-28	22	J-13	J-21	6.0	Ductile Iron	120.0	0.20	0.00	0.0000
91	P-29	19	J-12	J-23	6.0	Ductile Iron	120.0	3.72	0.04	0.0000
93	P-25(1)	69	J-17	J-24	8.0	Ductile Iron	120.0	0.96	0.01	0.0000
94	P-25(2)	24	J-24	J-18	6.0	Ductile Iron	120.0	0.96	0.01	0.0000
117	P-18(2)	70	J-11	J-12	8.0	Ductile Iron	120.0	6.31	0.04	0.0000
131	P-14(1)	240	J-7	J-28	8.0	Ductile Iron	120.0	7.91	0.05	0.0020
144	P-6(1)	73	FH125	J-29	8.0	Ductile Iron	120.0	7.91	0.05	0.0000
145	P-6(2)	53	J-29	J-7	8.0	Ductile Iron	120.0	7.91	0.05	0.0093
148	P-14(2)(1)	184	J-28	J-25	8.0	Ductile Iron	120.0	7.91	0.05	0.0026
149	P-14(2)(2)	28	J-25	J-8	8.0	Ductile Iron	120.0	6.31	0.04	0.0000
157	P-42	37	FH125	J-30	8.0	Ductile Iron	120.0	-7.91	0.05	0.0000
159	P-43	239	J-30	J-31	8.0	Ductile Iron	120.0	-7.91	0.05	0.0041
161	P-44	172	J-31	FH-179	16.0	Ductile Iron	120.0	-7.91	0.01	0.0000
164	P-45	11	R-4	PMP-4	16.0	Ductile Iron	120.0	7.91	0.01	0.0000

**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
165	P-46	15	PMP-4	FH-179	16.0	Ductile Iron	120.0	7.91	0.01	0.0000

# MAXIMUM DAY

**FlexTable: Junction Table**  
**FlexTable: Junction Table**

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
39	FH125	4,241.70	0.00	4,501.99	113
41	J-7	4,246.87	0.00	4,501.99	110
60	J-8	4,269.00	0.00	4,501.99	101
62	J-9	4,269.60	0.00	4,501.99	101
64	J-10	4,270.30	0.00	4,501.99	100
66	J-11	4,270.00	0.00	4,501.99	100
68	J-12	4,281.40	0.00	4,501.99	95
70	J-13	4,294.60	0.00	4,501.99	90
71	J-14	4,299.00	0.00	4,501.99	88
72	J-15	4,310.30	0.00	4,501.98	83
73	J-16	4,315.00	2.85	4,501.98	81
74	J-17	4,298.40	0.00	4,501.99	88
75	J-18	4,300.40	0.00	4,501.99	87
76	J-19	4,299.90	0.71	4,501.99	87
77	J-20	4,294.50	1.23	4,501.99	90
78	J-21	4,296.80	0.40	4,501.99	89
90	J-23	4,280.00	7.43	4,501.99	96
92	J-24	4,299.60	0.00	4,501.99	88
115	J-25	4,269.70	3.20	4,501.99	100
130	J-28	4,256.20	0.00	4,501.99	106
143	J-29	4,244.84	0.00	4,501.99	111
156	J-30	4,240.00	0.00	4,501.99	113
158	J-31	4,225.50	0.00	4,501.99	120
160	FH-179	4,225.00	0.00	4,501.99	120

**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
63	P-15	8	J-8	J-9	8.0	Ductile Iron	120.0	12.62	0.08	0.0000
65	P-16	7	J-9	J-10	8.0	Ductile Iron	120.0	0.00	0.00	0.0000
67	P-17	12	J-9	J-11	8.0	Ductile Iron	120.0	12.62	0.08	0.0000
79	P-19	86	J-12	J-13	8.0	Ductile Iron	120.0	5.19	0.03	0.0000
80	P-20	14	J-13	J-14	8.0	Ductile Iron	120.0	4.79	0.03	0.0000
81	P-21	81	J-14	J-15	6.0	Ductile Iron	120.0	2.85	0.03	0.0060
84	P-23	71	J-15	J-16	6.0	Ductile Iron	120.0	2.85	0.03	0.0000
85	P-24	45	J-14	J-17	8.0	Ductile Iron	120.0	1.94	0.01	0.0000
87	P-26	64	J-18	J-19	6.0	Ductile Iron	120.0	0.71	0.01	0.0000
88	P-27	18	J-18	J-20	6.0	Ductile Iron	120.0	1.23	0.01	0.0000
89	P-28	22	J-13	J-21	6.0	Ductile Iron	120.0	0.40	0.00	0.0000
91	P-29	19	J-12	J-23	6.0	Ductile Iron	120.0	7.43	0.08	0.0000
93	P-25(1)	69	J-17	J-24	8.0	Ductile Iron	120.0	1.94	0.01	0.0000
94	P-25(2)	24	J-24	J-18	6.0	Ductile Iron	120.0	1.94	0.02	0.0000
117	P-18(2)	70	J-11	J-12	8.0	Ductile Iron	120.0	12.62	0.08	0.0070
131	P-14(1)	240	J-7	J-28	8.0	Ductile Iron	120.0	15.82	0.10	0.0102
144	P-6(1)	73	FH125	J-29	8.0	Ductile Iron	120.0	15.82	0.10	0.0067
145	P-6(2)	53	J-29	J-7	8.0	Ductile Iron	120.0	15.82	0.10	0.0093
148	P-14(2)(1)	184	J-28	J-25	8.0	Ductile Iron	120.0	15.82	0.10	0.0106
149	P-14(2)(2)	28	J-25	J-8	8.0	Ductile Iron	120.0	12.62	0.08	0.0000
157	P-42	37	FH125	J-30	8.0	Ductile Iron	120.0	-15.82	0.10	0.0132
159	P-43	239	J-30	J-31	8.0	Ductile Iron	120.0	-15.82	0.10	0.0102
161	P-44	172	J-31	FH-179	16.0	Ductile Iron	120.0	-15.82	0.03	0.0000
164	P-45	11	R-4	PMP-4	16.0	Ductile Iron	120.0	15.82	0.03	0.0000

**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
165	P-46	15	PMP-4	FH-179	16.0	Ductile Iron	120.0	15.82	0.03	0.0000

# PEAK HOUR

**FlexTable: Junction Table**  
**FlexTable: Junction Table**

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
39	FH125	4,241.70	0.00	4,501.98	113
41	J-7	4,246.87	0.00	4,501.98	110
60	J-8	4,269.00	0.00	4,501.97	101
62	J-9	4,269.60	0.00	4,501.97	101
64	J-10	4,270.30	0.00	4,501.97	100
66	J-11	4,270.00	0.00	4,501.97	100
68	J-12	4,281.40	0.00	4,501.97	95
70	J-13	4,294.60	0.00	4,501.97	90
71	J-14	4,299.00	0.00	4,501.97	88
72	J-15	4,310.30	0.00	4,501.97	83
73	J-16	4,315.00	4.28	4,501.97	81
74	J-17	4,298.40	0.00	4,501.97	88
75	J-18	4,300.40	0.00	4,501.97	87
76	J-19	4,299.90	1.06	4,501.97	87
77	J-20	4,294.50	1.84	4,501.97	90
78	J-21	4,296.80	0.61	4,501.97	89
90	J-23	4,280.00	11.15	4,501.97	96
92	J-24	4,299.60	0.00	4,501.97	88
115	J-25	4,269.70	4.80	4,501.97	100
130	J-28	4,256.20	0.00	4,501.97	106
143	J-29	4,244.84	0.00	4,501.98	111
156	J-30	4,240.00	0.00	4,501.98	113
158	J-31	4,225.50	0.00	4,501.99	120
160	FH-179	4,225.00	0.00	4,501.99	120



**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
63	P-15	8	J-8	J-9	8.0	Ductile Iron	120.0	18.94	0.12	0.0618
65	P-16	7	J-9	J-10	8.0	Ductile Iron	120.0	0.00	0.00	0.0000
67	P-17	12	J-9	J-11	8.0	Ductile Iron	120.0	18.94	0.12	0.0000
79	P-19	86	J-12	J-13	8.0	Ductile Iron	120.0	7.79	0.05	0.0000
80	P-20	14	J-13	J-14	8.0	Ductile Iron	120.0	7.18	0.05	0.0000
81	P-21	81	J-14	J-15	6.0	Ductile Iron	120.0	4.28	0.05	0.0060
84	P-23	71	J-15	J-16	6.0	Ductile Iron	120.0	4.28	0.05	0.0069
85	P-24	45	J-14	J-17	8.0	Ductile Iron	120.0	2.90	0.02	0.0000
87	P-26	64	J-18	J-19	6.0	Ductile Iron	120.0	1.06	0.01	0.0000
88	P-27	18	J-18	J-20	6.0	Ductile Iron	120.0	1.84	0.02	0.0000
89	P-28	22	J-13	J-21	6.0	Ductile Iron	120.0	0.61	0.01	0.0000
91	P-29	19	J-12	J-23	6.0	Ductile Iron	120.0	11.15	0.13	0.0256
93	P-25(1)	69	J-17	J-24	8.0	Ductile Iron	120.0	2.90	0.02	0.0071
94	P-25(2)	24	J-24	J-18	6.0	Ductile Iron	120.0	2.90	0.03	0.0000
117	P-18(2)	70	J-11	J-12	8.0	Ductile Iron	120.0	18.94	0.12	0.0140
131	P-14(1)	240	J-7	J-28	8.0	Ductile Iron	120.0	23.74	0.15	0.0204
144	P-6(1)	73	FH125	J-29	8.0	Ductile Iron	120.0	23.74	0.15	0.0200
145	P-6(2)	53	J-29	J-7	8.0	Ductile Iron	120.0	23.74	0.15	0.0279
148	P-14(2) (1)	184	J-28	J-25	8.0	Ductile Iron	120.0	23.74	0.15	0.0212
149	P-14(2) (2)	28	J-25	J-8	8.0	Ductile Iron	120.0	18.94	0.12	0.0000
157	P-42	37	FH125	J-30	8.0	Ductile Iron	120.0	-23.74	0.15	0.0132
159	P-43	239	J-30	J-31	8.0	Ductile Iron	120.0	-23.74	0.15	0.0225
161	P-44	172	J-31	FH-179	16.0	Ductile Iron	120.0	-23.74	0.04	0.0000
164	P-45	11	R-4	PMP-4	16.0	Ductile Iron	120.0	23.74	0.04	0.0000

**FlexTable: Pipe Table**  
**FlexTable: Pipe Table**

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/1000ft)
165	P-46	15	PMP-4	FH-179	16.0	Ductile Iron	120.0	23.74	0.04	0.0000

# MAX DAY PLUS FIRE FLOW

**Fire Flow Node FlexTable: Fire Flow Report**  
**Fire Flow Node FlexTable: Fire Flow Report**

Label	Fire Flow Iterations	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (gpm)	Fire Flow (Available) (gpm)	Flow (Total Needed) (gpm)	Flow (Total Available) (gpm)	Pressure (Calculated Residual) (psi)	Pressure (Calculated Zone Lower Limit) (psi)	Velocity of Maximum Pipe (ft/s)
J-11	2	True	1,500.00	1,501.00	1,500.00	1,501.00	71	52	9.68
J-16	2	True	30.00	31.00	32.85	33.85	81	83	0.38
J-19	2	True	30.00	31.00	30.71	31.71	87	81	0.37
J-21	2	True	30.00	31.00	30.40	31.40	89	81	0.36
J-23	2	True	30.00	31.00	37.43	38.43	96	81	0.44
J-24	2	True	1,500.00	1,501.00	1,500.00	1,501.00	53	48	9.68